

Welcome Back!

pat@weghorstgroup.com

Recent Messages...

Message posted: 9/27/2021, 8:55:24 PM

IMPORTANT - As of 9/28, the calculation of "percent time in target" has been updated across all pages of Tech Assist. Cases and racks running with low temperature set points now use a range of +2.5 degrees above set point to -5 degrees below setpoint to determine if the case is running in target. Medium temperature cases still use a target range of +/- 2.5 degrees. As a result, you will most likely see a shift upwards in store, rack and case time in target percentages.

My Tech Assist Stores

Edit My Store List

Store Performance



8 # Stores 82.0% Avg. Time in Temperature 172 # Cases Outside of Target

Export Store List

Store	Link	Time in Target %	30 Day % Trend	# Cases Outside Target	# Open Workorders
1737 Villa Park, IL	[Click to View]	68.2		41/126	3
1892 Hodgkins, IL	[Click to View]	75.3		38/137	2
1003 Plano, IL	[Click to View]	79.7		19/120	2
2215 Darien, IL	[Click to View]	81.0		25/133	3
1779 Bridgeview, IL	[Click to View]	85.2		4/32	3
4405 Aurora, IL	[Click to View]	86.0		19/139	3
4286 Montgomery, IL	[Click to View]	88.1		16/139	2
1848 Glen Ellyn, IL	[Click to View]	93.0		10/120	0

Recently Viewed Stores

Showing last 10

Store	Analysis Date	Link	Last Viewed if	Target % When Viewed
1912	10/6/2021	[Click to View]	10/7/2021, 9:50:44 AM	66.3
1	10/5/2021	[Click to View]	10/6/2021, 11:08:41 AM	75.7
471	10/3/2021	[Click to View]	10/5/2021, 1:07:52 PM	74.5
5639	10/4/2021	[Click to View]	10/5/2021, 8:30:24 AM	80.1
899	10/4/2021	[Click to View]	10/5/2021, 8:30:15 AM	67.7
2814	10/3/2021	[Click to View]	10/4/2021, 5:54:21 PM	53.9
5912	10/3/2021	[Click to View]	10/4/2021, 5:01:06 PM	40.5
2391	9/23/2021	[Click to View]	10/4/2021, 5:00:57 PM	82.5
2129	9/27/2021	[Click to View]	9/30/2021, 7:27:36 PM	59.8
1237	8/31/2021	[Click to View]	9/29/2021, 3:26:26 PM	77.0

Recently Viewed Refrigeration Cases

Showing last 10

Store	Case	Analysis Date	Link	Class	Last Viewed if	Target % When Viewed
3463	b12	10/3/2021	[Click to View]	low temp unspecified frozen food	10/4/2021, 11:50:15 PM	56.0
3295	b6b	10/3/2021	[Click to View]	low temp coffin unspecified	10/4/2021, 11:49:14 PM	17.0
1237	c2a	10/3/2021	[Click to View]	med temp unspecified deli	10/4/2021, 11:29:32 PM	90.0
2129	a9b	9/27/2021	[Click to View]	low temp coffin unspecified	9/28/2021, 8:07:15 PM	0.0
7177	a4a	9/26/2021	[Click to View]	med temp door frozen food	9/27/2021, 8:07:21 AM	0.0
857	c15a	9/22/2021	[Click to View]	med temp coffin unspecified	9/23/2021, 12:18:03 PM	0.0
3409	a12a	9/22/2021	[Click to View]	low temp coffin unspecified	9/23/2021, 12:13:18 PM	0.0
525	b11a	9/4/2021	[Click to View]	med temp cooler produce	9/5/2021, 7:28:56 PM	30.0
7177	a6a	8/31/2021	[Click to View]	med temp door ice cream	9/3/2021, 3:30:56 PM	34.0
7177	b11b	8/31/2021	[Click to View]	med temp multi-deck deli	9/3/2021, 2:46:13 PM	0.0